



## IMPORTANT SAFEGUARDS READ AND FOLLOW ALL SAFETY INSTRUCTIONS.

When using electrical equipment, basic safety precautions should always be followed including the following:

- **DISCONNECT AC POWER SUPPLY BEFORE SERVICING.**
- Installation and servicing of this equipment should be performed by qualified service personnel only.
- Ensure that the electrical wiring conforms to the National Electrical Code NEC® and local regulations if applicable.
- Do not mount near gas or electrical heaters.
- Equipment should be mounted in locations and at heights where it will not be readily subjected to tampering by unauthorized personnel.
- The use of accessory equipment not recommended by the manufacturer may cause an unsafe condition.
- Any modification or use of non-original components will void the warranty and product liability.
- Do not use this equipment for other than intended use.

## SAVE THESE INSTRUCTIONS!

Technical Support ■ (623) 580-8943 ■ [technicalsupport@barronltg.com](mailto:technicalsupport@barronltg.com)

### Surface Mount

1. Remove the doorframe.
2. Disconnect the lead wires from the LED boards (quick connectors, make a note of connection order).
3. Remove the internal reflector.
4. Place base plate over mounting location.
5. Locate and drill pilot holes in mounting surface using the base plate as a template.
6. Using fasteners/anchors appropriate for the mounting surface and fixture weight, (supplied by others), mount the fixture base plate.
7. Run wiring leads into fixture and make the connections to the drivers. See **Electrical Connections** section.
8. Replace internal reflector and reconnect wires to LED strips.
9. Install doorframe and hand-tighten the fasteners.

### Electrical Connections

1. Connect the line fixture lead to the black supply lead.
2. Connect the neutral fixture lead to the white supply lead.
3. Connect the ground fixture lead to the green supply lead.
4. Connect the DIM+ fixture lead to the purple supply lead.
5. Connect the DIM- fixture lead to the pink supply lead.

