



# IMPORTANT SAFEGUARDS READ AND FOLLOW ALL SAFETY INSTRUCTIONS.

When using electrical equipment, basic safety precautions should always be followed including the following:

- DISCONNECT AC POWER SUPPLY BEFORE SERVICING.
- · Installation and servicing of this equipment should be performed by qualified service personnel only.
- Ensure that the electrical wiring conforms to the National Electrical Code NEC® and local regulations if applicable.
- Do not mount near gas or electrical heaters.
- Do not use outdoors.
- Equipment should be mounted in locations and at heights where it will not be readily subjected to tampering by unauthorized personnel.
- The use of accessory equipment not recommended by the manufacturer may cause an unsafe condition.
- · Any modification or use of non-original components will void the warranty and product liability.
- Do not use this equipment for other than intended use.

#### SAVE THESE INSTRUCTIONS!

**Technical Support** ■ (623) 580-8943 ■ technical support@barronltg.com





### **DMX-RGBW-WHEEL**


Installation Instructions





- 1. Install the junction box into the wall. (Fig. 1)
- 2. Use screwdriver to gently pry out the backplate from the touch panel. (Fig. 2)
- 3. Screw the backplate and junction box firmly into the wall. (Fig 3)
- 4. Make proper connections and place power adapter inside junction box. (Fig. 4)
- 5. Place the touch panel into the backplate. Then, push the bottom of touch panel into the slot. (Fig. 5)












#### **DMX-RGBW-WHEEL**

Installation Instructions





#### **Key Functions**



The Changing Mode (Press 1888 to Select)

- 1. Static Red
- 2. Static Green
- 3. Static Blue
- 4. Static Yellow
- 5. Static Purple
- 6 . Static Cyan
- 7. Static White
- 8. RGB Jumping
- 9. 7 Colors Jumping
- 10. RGB Smooth
- 11.7 Colors Smooth
- 12. Static Black





- 5. Press and hold the power key on the panel for three seconds. The panel light on Panel A should turn on. (Fig. 6)
- 6. Press any key on any zone of Panel B. If the indicator lights on Panel A stop blinking, the connection is successful. (Fig. 6)
- 7. Press keys I and IV simultaneously for more than six seconds to deactivate and clear code. If the light indicator blinks three times, it has been successfully deactivated. (Fig. 7)



## **DMX-RGBW-WHEEL**

Installation Instructions



**DMX Output Wiring** 

