

SAVE THESE INSTRUCTIONS!

READ CAREFULLY AND FOLLOW ALL INSTRUCTIONS FOR YOUR OWN SAFETY

- **DISCONNECT AC POWER SUPPLY BEFORE SERVICING.**
- Installation and servicing of this equipment should be performed by qualified service personnel only.
- Ensure the electricity connections conform to the National Electrical Code and local regulations if applicable.
- Do not mount near gas or electrical heaters.
- Equipment should be mounted in locations and at heights where it will not readily be subjected to tampering by unauthorized personnel.
- The use of accessory equipment not recommended by the manufacturer may cause an unsafe condition. Any modification or use of non-original components will void the warranty and product liability.
- Do not use this equipment for other than intended use.



INSTALLATION INSTRUCTIONS

1. Remove mounting plate from fixture by loosening (2) set screws.
2. Attach mounting plate to recessed junction box using hardware provided with junction box ensuring plate is level.
3. Thread stud into stud hole.
4. Electrical connections should be made inside junction box. Cap all unused leads to prevent shorting.
This fixture auto adjust for voltage between 120VAC to 277VAC.
 - a. Connect the line fixture lead to the black supply lead.
 - b. Connect the common fixture lead to the white supply lead
 - c. Connect the ground lead from the service to the green grounding screw.
5. Use approved connectors to connect fixture leads to supply leads and make wire splices inside junction box.
6. Care should be taken when mounting fixture not to pinch leads. Align mounting hole with threaded stud and push fixture up against mounting plate.
7. Secure fixture by tighten the (2) set screws on the mounting plate.

NOTE: * Wet locations installation: Construction is suitable for Down-light.
* Damp locations installation: Construction is suitable for Up-light.

IMPORTANT

To weather-proof your outdoor installation, be sure to seal all holes in fixture housing. (Mounting, conduit, plugs and photo controls, etc.) with silicone sealant. Apply sealant across top edge of wall pack to prevent water from reaching the back of the housing.

TROUBLE SHOOTING

TLED112 does not turn "ON"

1. Check incoming voltage to LED driver. Must be at least a minimum of 120VAC and no greater than 277VAC.
2. Are all the LEDs on the light engine "OFF"? If so, LED driver may be defective. Using a voltmeter, check to see if voltage is present at the output of power supply. If low or no voltage, then replace power supply.
3. If any individual LEDs are "OFF" the LED light engine is defective. Please have the serial number off the light engine available when you contact technical support.

LED MODULE REPLACEMENT

1. Remove heatsink from housing by removing (3) screws "A".

Note: Spacers located behind heatsink set aside for reuse.

2. Cut connector off LED module and driver and discard.
3. Loosen (4) screws "B" holding LED module to heatsink and discard old module.
4. Install new LED module, feeding wires from module through holes in heatsink, retighten screws "B".
5. Use approved wire nuts to connect LED module leads to leads from driver, observing polarity.
6. Reinstall heatsink to housing reversing procedure in step 1.

